

**IEC****IECEE**

Ref. Certif. No.

**FR\_714619**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

**Switching element**

Name and address of the applicant

**LEGRAND FRANCE**  
159 RUE JEAN JOANNON  
ZI DES TROIS MOULINS  
06606 ANTIBES - FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
290 AVENUE DE COLMAR  
67100 STRASBOURG - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Electrical emergency stop device  
Series OSMOZ  
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_60044594A dated 26/06/2006. Update further to the evolution of the standard(s), update the list of product references

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60947-5-5:1997, AMD1:2005, AMD2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

172883-766122B, 172883-766122B1

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE[www.lcie.fr](http://www.lcie.fr)LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSESSignature:   
**Julien GAUTHIER**  
Certification Officer

Date: 24/05/2022

## ANNEX

**Name and address of the factories:**


**LEGRAND FRANCE**  
290 AVENUE DE COLMAR  
67100 STRASBOURG – FRANCE

**LEGRAND POLSKA SP. Z O.O.**  
UL. WARYNSKIEGO 20  
57-200 ZABKOWICE SLASKIE - POLAND



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 24/05/2022



Signature:   
**Julien GAUTHIER**  
Certification Officer

### ANNEX

Classification of installation and use	Electrical emergency stop device
Kind of switching elements	auxiliary contacts of a switching device (e.g. contactor, circuit-breaker, etc) which are not dedicated exclusively for use with the coil of that device
Number of poles	1 and 2
Kind of current	AC and/or DC
Method of operations	manual
Method of control	Non-automatic
Rated operational voltage Ue (V)	AC: 120V / 6 A – 240 V / 3 A - 600 V / 1,2 A
Rated operational current Ie (A)	DC: 125 V / 0,55 A – 250 V / 0,27 A - 600 V / 0,1 A
Rated insulation voltage Ui (V)	690V
Rated impulse withstand voltage Uimp (kV)	6kV
Conventional free air thermal current Ith (A)	10A AC; 2.5A DC
Conventional enclosed thermal current Ithe (A)	10A AC ; 2.5A DC
Rated frequency ( Hz)	50 / 60 Hz
IP Code	IP65
Pollution degree	3



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 24/05/2022



LABORATOIRE CENTRAL DES  
 INDUSTRIES ELECTRIQUES  
 S.A.S au capital de 15.745.984 €  
 RCS Nanterre B 408 363 174  
 33 avenue du Général Leclerc  
 F - 92266 FONTENAY AUX ROSES

Signature:  **Julien GAUTHIER**  
 Certification Officer

**ANNEX**
Switching element: contact blocks

References trademark LEGRAND	Designation
0 229 01	NC BLOCK SCREW
0 229 02	NO BLOCK SCREW
0 242 41	REAR NC BLOCK SCREW
0 242 42	REAR NO BLOCK SCREW

Clips

References trademark LEGRAND	Designation
0 229 60	Osmoz clip - 1 position
0 229 64	Osmoz clip - 3 positions
0 229 68	Osmoz clip - 5 positions

Emergency stop heads

References trademark LEGRAND	Designation
0 238 85	Emergency stop Ø40 - Stay-put - push-turn - red
0 238 74	Emergency stop Ø40 - Stay-put - push-pull - red
0 238 92	Emergency stop Ø40 - Stay-put - with key - red
0 240 82	Emergency stop illuminated Ø40 - Stay-put - push-pull - red
0 238 94	Emergency stop Ø54 - Stay-put - push-pull with flag indicator - red O-I
0 238 95	Emergency stop Ø54 - Stay-put - push-pull with flag indicator - red STOP-I



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 24/05/2022



Signature: **Julien GAUTHIER**  
 Certification Officer