




CB TEST CERTIFICATE

Ref. Certificate No.

IT-10651/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	IMQ S.p.A.		
Product:	Circuit-breakers for overcurrent protection for household and similar installations		
Applicant:	LEGRAND SNC	128 AVENUE DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX	France
Manufacturer:	BTICINO S.p.A. - LEGRAND GROUP	VIALE BORRI 231 21100 VARESE	Italy
Factory: <small>nb: Additional factory information on page 2</small>	BTICINO S.p.A. - LEGRAND GROUP	VIA DELLE INDUSTRIE 22 80059 TORRE DEL GRECO (NA)	Italy
Rating and principal characteristics:	1P (230/400 V); 2P; 3P; 4P (400 V); 50/60 Hz; In 0,5 to 63 A; Type B-C-D; Icn 6000 A (see Test Report Ref. No. PB13A0139689-01-00)		
Trade mark (if any):	legrand 		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	Series DX ³ (see Additional Sheet)		
Additional information:	This CB Test Certificate is an Appendix to CB Test Certificate No. IT-10651 dated 2011-04-19 and they must be read in conjunction. Modification introduced: see details on the "General product information" section on page 5 of 12 of Test Report Ref. No. PB13A0139689-01-00.		
Sample of product tested to be in conformity with IEC:	60898-1(ed.1);am1;am2	National differences: EU Group Differences	
Test Report Ref. No:	from PB13A0139689-01-00 to PB13A0139689-01-18		

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2013-11-27





IEC SYSTEM FOR CONFORMITY
TESTING TO STANDARDS FOR
SAFETY OF ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Ref. Certificate No.

IT-10651/M1

Legrand Polska UL.

Legrand Polska UL. Warynskiego, 20
Zabkowice Slaskie
Poland

Legrand Elektrik San AS.

GOSB Gebze Organize Sanayi Bolgesi
Ihsan Dede cad. No: 112
Gebze - KOCAELI
Turkey

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2013-11-27



Description of the type reference of the circuit-breakers Series DX³ - object of the modification:

Curve	In (A)	1P	2P	3P	4P	Type of modification *
B	1	4074 25	4075 02	4075 54	4076 17	1 - 2 - 3 - 4
	2	4074 26	4075 03	4075 55	4076 18	
	3	4074 27	4075 04	4075 56	4076 19	
	4	4074 28	4075 05	4075 57	4076 20	
	6	4074 29	4075 06	4075 58	4076 21	
	10	4074 30	4075 07	4075 59	4076 22	
	13	4074 31	4075 08	4075 60	4076 23	
	16	4074 32	4075 09	4075 61	4076 24	
	20	4074 33	4075 10	4075 62	4076 25	
	25	4074 34	4075 11	4075 63	4076 26	
	32	4074 35	4075 12	4075 64	4076 27	2 - 3 - 4
	40	4074 36	4075 13	4075 65	4076 28	
	50	4074 37	4075 14	4075 66	4076 29	
	63	4074 38	4075 15	4075 67	4076 30	
C	1	4076 62	4077 92	4078 51	4079 20	1 - 2 - 3 - 4
	2	4076 63	4077 93	4078 52	4079 21	
	3	4076 64	4077 94	4078 53	4079 22	
	4	4076 65	4077 95	4078 54	4079 23	
	6	4076 66	4077 96	4078 55	4079 24	
	10	4076 68	4077 98	4078 57	4079 26	
	13	4076 69	4077 99	4078 58	4079 27	
	16	4076 70	4078 00	4078 59	4079 28	
	20	4076 71	4078 01	4078 60	4079 29	
	25	4076 72	4078 02	4078 61	4079 30	
	32	4076 73	4078 03	4078 62	4079 31	2 - 3 - 4
	40	4076 74	4078 04	4078 63	4079 32	
	50	4076 75	4078 05	4078 64	4079 33	
	63	4076 76	4078 06	4078 65	4079 34	
D	0,5	4079 62	4080 22	4080 80		1 - 2 - 3 - 4
	1	4079 63	4080 23	4080 81		
	2	4079 64	4080 24	4080 82		
	3	4079 65	4080 25	4080 83		
	4	4079 66	4080 26	4080 84		
	6	4079 67	4080 27	4080 85	4081 43	
	10	4079 69	4080 29	4080 87	4081 45	
	13	4079 70	4080 30	4080 88	4081 46	
	16	4079 71	4080 31	4080 89	4081 47	
	20	4079 72	4080 32	4080 90	4081 48	
	25	4079 73	4080 33	4080 91	4081 49	2 - 3 - 4
	32	4079 74	4080 34	4080 92	4081 50	
	40	4079 75	4080 35	4080 93	4081 51	
	50	4079 76	4080 36	4080 94	4081 52	
63	4079 77	4080 37	4080 95	4081 53		

* See details on the "General product information" section on page 5 of 12 of Test Report Ref. No. PB13A0139689-01-00