



ASSOCIAZIONE PER LA CERTIFICAZIONE  
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 – 24123 – BERGAMO (Italy)  
Tel. +390354175244 fax. +390354534662 e-mail: [acaecert.it](mailto:acaecert.it)



# Certificate of Conformity

LOVAG-Certificate No. IT 14.019

This certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition.

The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus Tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

**Apparatus** Four poles modular circuit breaker  
415V ( $U_e$ ) – 32A ( $I_n$ ) – 16kA at 415 ( $I_{cu}$ ) 50/60Hz  
12kA at 415V ( $I_{cs}$ )

**Designation** DX<sup>3</sup> 32A 16kA curve “C” 4P

**Manufacturer or responsible vendor:**  
Legrand S.n.c. -128, Av. du Maréchal-de-Lattre-de-Tassigny-  
87045 Limoges Cedex (France)

**Tested for:** Legrand S.n.c.

**Tested by:** ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with  
Standard IEC 60947-2: Ed.4.1 (2013-01)+A1 (2009-07)+A2 (2013-01)  
EN 60947-2: (2006-08)+ A1 (2009-07)+A2 (2013-01)  
Sequence II and III

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated in below.

16kA at 415 ( $I_{cu}$ )  
12kA at 415V ( $I_{cs}$ )

This document includes Test report No.: 138  
Issue date: 2014.03.04

Responsible Certification Body : ACAE  
Virginio Scarioni

Authorized signature

Date: 2014.03.25



PRD N°070B  
Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements