

CB TEST CERTIFICATE

Ref. Certificate No.

IT-14270

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: IMQ S.p.A.

Product: Circuit-breakers for overcurrent protection for household and similar installations


Applicant: LEGRAND SNC 128 AVENUE DE LATTRE France
DE TASSIGNY
87045 LIMOGES CEDEX

Manufacturer: BTICINO S.p.A. - VIALE BORRI 231 Italy
LEGRAND GROUP 21100 VARESE

Factory: BTICINO S.p.A. - VIA DELLE INDUSTRIE 22 Italy
LEGRAND GROUP 80059 TORRE DEL
GRECO (NA)

nb: Additional factory information on page 2

Rating and principal characteristics: 1P (230/400 V); 1P+N (230V); 2P; 3P; 4P (400 V);
50/60 Hz; In 6 A to 63 A - Type B-C; Icn 6000 A (see
Test Report Ref. No. PB14S0219784-02-00)

Trade mark (if any): legrand


Type of Manufacturer's Testing Laboratories used: WMT

Model/Type reference: Series RX³ Germanic (see Additional Sheet)

Additional information:

Sample of product tested to be in conformity with IEC: 60898-1(ed.1);am1;am2 National differences:
EU Group Differences

Test Report Ref. No: from PB14S0219784-02-00 to PB14S0219784-02-40


This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Fulvio Giorgi

Date of issue: 2014-05-06





IEC SYSTEM FOR CONFORMITY TESTING
TO STANDARDS FOR SAFETY OF
ELECTRICAL EQUIPMENT (IECEE) CB
SCHEME

Ref. Certificate No.

IT-14270

Legrand Polska UL.

Warynskiego, 20
Zabkowice Slaskie
Poland

Legrand Elektrik Sanayi AS.

GOSB Gebze Organize Sanayi Bolgesi
İhsan Dede cad. No: 112 - Marmara
Gebze - KOCAELI
Turkey

**Legrand India (Novateur electrical & Digital
Systems Private Limited)**

D-4 MIDC Industrial Estate,
Ajanta Road – Maharashtra,
425003 Jalgaon
India

**Legrand China – Wuxi (Legrand Low Voltage
Electrical)**

N° 88 Ximei Road, New district–Wuxi
Jiangsu Province
214028 Wuxi
China

EMB Electrical Industries S.A.E.

Sadat City Factory, 2nd Industrial Zone
Monufya
32958 Sadat City
Egypt

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Fulvio Giorgi

Date of issue: 2014-05-06



Description of the type reference of the Series RX³ Germanic

Curve	Rated current	1P	1P+N (N left side)	2P	3P	4P
B	6 A	419133	LG3656	419155	419166	LG3694
	8 A	LG3650	LG3657	LG3682	LG3688	LG3695
	10 A	419134	LG3658	419156	419167	LG3696
	13 A	419135	LG3659	419157	419168	LG3697
	15 A	LG3651	LG3660	LG3683	LG3689	LG3698
	16 A	419136	LG3661	419158	419169	LG3699
	20 A	419137	LG3662	419159	419170	LG3700
	25 A	419138	LG3663	419160	419171	LG3701
	32 A	419139	LG3664	419161	419172	LG3702
	40 A	419140	LG3665	419162	419173	LG3703
	45 A	LG3652	LG3666	LG3684	LG3690	LG3704
	50 A	419141	LG3667	419163	419174	LG3705
	63 A	419142	LG3668	419164	419175	LG3706
C	6 A	419199	LG3669	419221	419232	LG3707
	8 A	LG3653	LG3670	LG3685	LG3691	LG3708
	10 A	419200	LG3671	419222	419233	LG3709
	13 A	419201	LG3672	419223	419234	LG3710
	15 A	LG3654	LG3673	LG3686	LG3692	LG3711
	16 A	419202	LG3674	419224	419235	LG3712
	20 A	419203	LG3675	419225	419236	LG3713
	25 A	419204	LG3676	419226	419237	LG3714
	32 A	419205	LG3677	419227	419238	LG3715
	40 A	419206	LG3678	419228	419239	LG3716
	45 A	LG3655	LG3679	LG3687	LG3693	LG3717
	50 A	419207	LG3680	419229	419240	LG3718
63 A	419208	LG3681	419230	419241	LG3719	