




# CB TEST CERTIFICATE

Ref. Certificate No.

IT-11142

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	IMQ SpA		
Product:	Residual current units		
Applicant:	LEGRAND SNC	128 Avenue De Lattre De Tassigny 87045 LIMOGES CEDEX	France
Manufacturer:	BTICINO S.p.A. - LEGRAND GROUP	Viale Borri 231 21100 VARESE (VA)	Italy
Factory: <small>nb: Additional factory information on page 2</small>	BTICINO S.p.A. - LEGRAND GROUP	Via Delle Industrie 12 80059 TORRE DEL GRECO (NA)	Italy
Rating and principal characteristics:	2P (230/400V); 3P - 4P (400V); 50Hz; In max 40A and max 63A; I $\Delta$ n 30-300-1000mA; Type AC-A-AS-ACS (see on pages 8, 9 and 10 of Test Report no. 03SL00009-00)		
Trade mark (if any):	legrand 		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	Series DX <sup>s</sup> (see on pages 8 and 9 of Test Report no. 03SL00009-00)		
Additional information:			
Sample of product tested to be in conformity with IEC:	61009-1(ed.3) 61009-2-1(ed.1)	<b>National differences:</b> EU Group Differences	
Test Report Ref. No:	03SL00009-00; from 03SL00009-01 to 03SL00009-64		

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.  
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari 

Date of issue: 2011-09-27





IEC SYSTEM FOR CONFORMITY  
TESTING TO STANDARDS FOR  
SAFETY OF ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Ref. Certificate No.

IT-11142

**COZZOLINO DOMENICO EREDI s.a.s. di  
Mazza M. e Cozzolino F.**  
Via Giovanni XXIII, 55  
80059 TORRE DEL GRECO (NA)  
Italy

**ELETTROLAMP S.r.l.**  
c.da Sant'Anna snc  
82019 SANT'AGATA DEI GOTI (BN)  
Italy

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

IMQ SpA  
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2011-09-27

