



Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 592714A

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE / CERTIFICAT D'ESSAI OC

SOCKET-OUTLET

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

16A, 250V~



Gamme / Series: Appareillage Saillie

Références voir annexe 1 / References see annex 1

Voir annexe 1 / See annex 1

Annule et remplace le certificat d'essai OC / Supersedes the CBTC
n° FR 2738/1/17441 dated 2003/11/26

Suppression et ajout de références / Deletion and addition of
references

PUBLICATION

EDITION

IEC 60884-1:2002 (third edition) +A1:2006

Test report n° 17441040/7


Laboratoire Central des Industries Électriques


33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



Date: 2010-01-20

Signature


Jean-François BRUEL
Certification Officer



Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 592714A

Annex 1

RATING AND PRINCIPAL CHARACTERISTICS

References		Fonction	Characteristics	Remarks
Complete unit	Mechanism + cover plate			
86031	86131	2P +T	16A / 250 V~	with shutters
86029	86129	2P +T	16A / 250 V~	without shutters
86067		6 + 2P+T	10AX + 16A/250 V~	with shutters
86077		2 x 2P+T	16A / 250 V~	with shutters

CLASSIFICATION

standard Sheet	III (CEE 7)
rated current (A)	16A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
degree of protection against electric shock	normal protection
existence of shutters	without and with shutters
method of application - mounting	surface-type
method of installation	design A
colour	white or brown

Accessories

Surface mounting frame	References
1 gang	86091
2 gang	86092
3 gang	86093

Laboratoire Central des Industries Électriques
33,av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



2010-01-20

Signature

Jean-François BRUEL
Certification Officer