



Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 593474B

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE / CERTIFICAT D'ESSAI OC

SOCKET-OUTLET

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

16A, 250V~, 2P+T/2P+E



Gamme / Series MOSAIC
Référence/ Reference : 77131

Voir annexe 1 / See annex 1

PUBLICATION

EDITION

IEC 60884-1:2002 (third edition) +A1:2006

Rapport d'essai / Test report n°97303-593449

National de Certification



Laboratoire Central des Industries Électriques

33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr


Date

2010-03-16

Signature

Jean-François LEL
Certification Officer





Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 593474B

Annex 1

RATING AND PRINCIPAL CHARACTERISTICS

Easy to handle socket-outlet of Mosaic series: reference 77131


CLASSIFICATION

| | |
|---|--|
| standard Sheet: | V (CEE 7) |
| rated current (A) | 16A |
| rated voltage (V) | 250V |
| degree of protection | IP20 |
| provision for earthing | with earthing contact |
| method of connecting the cable | rewirable |
| type of terminals | screwless (rigid and flexible) |
| colour | white |
| degree of protection against electric shock | normal protection increased protection |
| existence of shutters | with shutters |
| method of application - mounting | flush-type |
| method of installation | design A |

Additional information if necessary:
informations complémentaires si nécessaire

Laboratoire Central des Industries Électriques

33,av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



Date: 2010-03-16

Signature:

Jean-François BRUEL
Certification Officer