



Ref. Certif. No.

HU-001259-A4/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet

Name and address of the applicant

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentés, Hungary

Name and address of the manufacturer

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentés, Hungary

Name and address of the factory

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentés, Hungary*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

250V~, 16A;
Standards Sheet: IEC 60083:1975 St. Sh. C2a;
with side-earthing contact; rewirable
(refer to Test Report for further details)

Trademark (if any))

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Design: „Mosaic“ and „ARTEOR“
(See General product information of Test Report for
the list of type variants)Additional information (if necessary may also be
reported on page 2)This Certificate is modification No.1 to CBTC ref. No.
HU-001259, dated 2014-02-18 with amendments No. A1,
A2, A3, A4 and it is issued due to change of
construction
(See details in Test Report)A sample of the product was tested and found
to be in conformity with

IEC 60884-1:2002 + AMD1:2006 + AMD2:2013

As shown in the Test Report Ref. No. which forms part
of this Certificate

28220817 009

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2018-06-06

Signature:

Gabor Kassa