

IEC**IECEE**
CB
SCHEMEAccréditation
N° 5-0014
Portée
disponible sur
www.cofrac.fr

Ref. Certif. No.

FR 570469AIEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**
CERTIFICAT D'ESSAI OCProduct
Produit

SOCKET-OUTLET

Name and address of the applicant
Nom et adresse du demandeur**LEGRAND FRANCE**
128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - FranceName and address of the manufacturer
Nom et adresse du fabricant**LEGRAND FRANCE**
128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - FranceName and address of the factory
Nom et adresse de l'usine**VIDEOTON BULGARIAN HOLDINGS LTD.**
DZU AD 10th NICOLA PETKOVth Blvd. - 6000 STARA ZAGORA - BulgariaNote : When more than one factory, please report on page 2
Note : Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

16A, 250V~

Trademark (if any)
Marque de fabrique (si elle existe)

LEGRAND

Model / Type Ref.
Ref. De typeSeries CARIVA
References see annex 1Additional information (if necessary may also be
reported on page 2)
Informations complémentaires (si nécessaire, peuvent
être indiquées sur la 2^{ème} page)See annex 1
Supersedes the certificate n° FR 60042612B1
Change of factory**PUBLICATION****EDITION**

IEC 60884-1:2002 (third ed)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

Test reports n° 60031817-532410-1, 60031817-532410B

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce CertificatThis CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification**Laboratoire Central des Industries Électriques**33, av du Général Leclerc - BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date: 2008-05-22

Signature:

Jean-François BRUEL
Certification Officer

Annex 1

Sockets: series CARIVA

Designation	Rated values	Reference type	Catalogue references			
			One piece units		Modular	
			Colour Ivory	Colour White	Colour Ivory	Colour White
2P+E, Earthing pin type	16A, 250V~	BMD010	773924	773824	773724	773624
2P+E, Earthing pin type, with shutter	16A, 250V~	BMD010	773925	773825	773725	773625
2P+E, Earthing pin type, with shutter, IP44	16A, 250V~	BMD010	773928	773828	773728	773628

Cover plates

Colour	1 gang	2 gang	3 gang	4 gang
White	773651	773652	773653	773654
Ivory	773751	773752	773753	773754
Gold	773661	773662	773663	773664
Aluminium	773671	773672	773673	773674
Beige	773681	773682	773683	773684
Grey bead	773691	773692	773693	773694
REF TYPE	BMDM1	BMDM2	BMDM3	BMDM4

RATING AND PRINCIPAL CHARACTERISTICS

CLASSIFICATION

standard Sheet:	V (cee 7)
rated current (A) / rated voltage (V)	16A / 250V
degree of protection	IP20 – IP44 (see above)
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
socket-outlets	
degree of protection against electric shock	normal protection
existence of shutters	without shutters - with shutters (see above)
method of application - mounting	flush-type
method of installation	design A

Additional Information (if necessary)
Informations complémentaires (si nécessaire)



Laboratoire Central des Industries Électriques
33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date: 2008-05-22

Signature:

Jean-François BRUEL
Certification Officer

