



Ref. Certif. No.

HU-002621

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Flush type socket-outlet

Name and address of the applicant

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentés, Hungary

Name and address of the manufacturer

Legrand Elektrik Sanayi A.S.
Gebze Organize Sanayi Bolgesi, Ihsan Dede Caddesi 112,
41480 Kocaeli, Turkey

Name and address of the factory

Legrand Elektrik Sanayi A.S.
Gebze Organize Sanayi Bolgesi, Ihsan Dede Caddesi 112,
41480 Kocaeli, Turkey

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

250V~; 16A, IP20, IP44
(refer to Test Report for further details)

Trademark (if any)

legrand

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Design: "Raventi", "Niloe", "Niloé step" socket-outlets with pin-type earthing contact
(see Test Report for details)

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002 + AMD1:2006 + AMD2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

28249538 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft, Division MEEI
H-1132 Budapest, Váci út 46/A-B
www.tuv.com

Date: 2019-06-12

Signature:



1. Ferencne Schmidt