

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-003554

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

"Suno" double socket-outlets with earthing contacts

Name and address of the applicant

LEGRAND Magyarország Villamossági Rendszerek ZRt.
Ipartelepi út 14.
6600 Szentes, Hungary

Name and address of the manufacturer

LEGRAND Magyarország Villamossági Rendszerek ZRt.
Ipartelepi út 14.
6600 Szentes, Hungary

Name and address of the factory

LEGRAND Magyarország Villamossági Rendszerek ZRt.
Ipartelepi út 14.
6600 Szentes, Hungary

Ratings and principal characteristics

250 V~; 16 A; IP20
(see Test Report for further ratings)

Trademark (if any)

See test report for logo

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SUDS12, SUCD12, SUDF12, SUDF21
(SUNO family)
/See Test Report for details/

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

HU21TVZF 001

This CB Test Certificate is issued by the National Certification Body


TÜVRheinland®

 TÜV Rheinland InterCert Kft., MEEI Division
 H-1143 Budapest, Gizella út 51-57., Hungary
 Web: www.tuv.com

Date: 2021-07-26

Signature:

Petra Szabadi