



Certificate of Conformity

LOVAG-Certificate No.: IT 18.047
Page 1 of 2

Apparatus Low-voltage assembly

415 V (U_n) – 690 V (U_i) – 8 kV (U_{imp}) – 50 Hz (f) – 3065 A (I_{nA}) – 50 kA (I_{cc}) – 50 kA (I_{cw}) x 1 s (t) – IP40

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate



Designation Type XL³ S 4000 Arrangement 143

Manufacturer Legrand SNC
128, Avenue du Marechal du Lattre de Tassigny
87045 Limoges Cedex - France

Applicant: Legrand SNC
128, Avenue du Marechal du Lattre de Tassigny
87045 Limoges Cedex - France

Verified by: ACAE Laboratory IB01

The apparatus, constructed in accordance with the description mentioned in the Report listed in this Certificate has been subjected to the series of proving verifications in accordance with

IEC 61439-2 Ed.2.0 (2011-08) and EN 61439-2 (2011-10):

- 10.11.5.3 Short-circuit withstand strength

The results are shown in the Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated at pages no. 2



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Responsible Certification Body: ACAE
Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

Authorized Signature: Virginio Scarioni
Date: 2018.04.05



Certificate of Conformity

LOVAG-Certificate No.: IT 18.047
Page 2 of 2



Circuit		D1 Incomer	Main copper busbar	Vertical Alu busbar 2x F7436	Horiz. upper busbar	Vertical Alu busbar 2x F7437
Rated operational voltage (U_e) V		415	415	415	415	415
Rated insulation voltage (U_i) V		1000	1000	1000	1000	1000
Loading condition 1	Rated current (I_{nc}) A	3065	3065	2340	1260	1260
	Rated diversity factor	1	1	1	1	1
Loading condition 2	Rated current (I_{nc}) A	3065	3065	1115	1115	1115
	Rated diversity factor	1	1	1	1	1
Rated short-time withstand current (I_{cw}) kA – (t) s		50–1	50–1	50–1	50–1	50–1
Rated peak withstand current (I_{pk}) kA		105	105	105	105	105
Rated conditional short-circuit current (I_{cc}) kA		50	50	50	50	50

Circuit		D2	D3	D4	D5	D6	D7
Rated operational voltage (U_e) V		415	415	415	415	415	415
Rated insulation voltage (U_i) V		1000	1000	690	690	690	690
Loading condition 1	Rated current (I_{nc}) A	725	1080	1080	0	180	0
	Rated diversity factor	1	1	1	-	1	-
Loading condition 2	Rated current (I_{nc}) A	1950	0	343	470	190	112
	Rated diversity factor	1	-	1	1	1	1
Rated short-time withstand current (I_{cw}) kA – (t) s		-	-	-	-	-	-
Rated peak withstand current (I_{pk}) kA		-	-	-	-	-	-
Rated conditional short-circuit current (I_{cc}) kA		50	50	50	50	50	50

This document includes : Test Report No. 1356
Issue date: 2018.03.19



Responsible Certification Body: ACAE
Via Tito Livio, 5 - 24123 – BERGAMO (Italy)

Authorized Signature: Virginio Scarioni
Date: 2018.04.05