


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Plugs, socket-outlets and couplers for industrial purposes
Name and address of the applicant	LEGRAND FRANCE 6, rue Paul Nouel - CS 80008 76770 MALAUNAY FRANCE
Name and address of the manufacturer	LEGRAND FRANCE 6, rue Paul Nouel - CS 80008 76770 MALAUNAY FRANCE
Name and address of the factory	LEGRAND ELEKTRIK SANAYI A.S GOSB GEBZE ORGANIZE SANAYI BOLGESI - IHSAN DEDE CADDESI N°112 41480 GEBZE KOCAELI TURKEY
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Models P17 Tempra Pro References : 555xxx see annex
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR 641754/A1 dated 21/12/2015, update of test report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60309-1:1999(ed. 4) +A1:2005 +A2:2012 IEC 60309-2:1999(ed. 4) +A1:2005 +A2:2012
As shown in the Test Report Ref. No. which forms part of this Certificate	169087-756205

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 28/01/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer


ANNEX

References, ratings and main characteristics:

Panel mounting socket-outlet					References	
Current	Number of poles	Voltage	Frequency	Earthing position	IP 44	IP 66-67
16 A	2P+T	100/130 V	50 / 60 Hz	4	555181	555381
16 A	2P+T	200/250 V	50 / 60 Hz	6	555184	555384
16 A	3P+T	200/250 V	50 / 60 Hz	9	555185	555385
16 A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555186	555386
16 A	3P+T	380/415 V	50 / 60 Hz	6	555188	555388
16 A	4P+T	200/346 V to 240/415 V	50 / 60 Hz	6	555189	555389
16 A	3P+T	440/460 V	60 Hz	11	555190	
16 A	3P+T	480/500 V	50 / 60 Hz	7	555192	555392
16 A	4P+T	277/480 V to 288/500 V	50 / 60 Hz	7	555193	
32 A	2P+T	100/130 V	50 / 60 Hz	4	555281	555481
32 A	2P+T	200/250 V	50 / 60 Hz	6	555284	555484
32 A	3P+T	200/250 V	50 / 60 Hz	9	555285	555485
32 A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555286	555486
32 A	3P+T	380/415 V	50 / 60 Hz	6	555288	555488
32 A	4P+T	200/346 V to 240/415 V	50 / 60 Hz	6	555289	555489
32 A	3P+T	440/460 V	60 Hz	11	555290	
32 A	3P+T	440 V	60 Hz	11		555491
32 A	3P+T	480/500 V	50 / 60 Hz	7	555292	555492
32 A	4P+T	277/480 V to 288/500 V	50 / 60 Hz	7	555293	



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: Julien Gauthier
Certification Officer


Date: 28/01/2021

ANNEX (Continued)

Surface mounting socket					References	
Current	Number of poles	Voltage	Frequency	Earthing position	IP 44	IP 66-67
16 A	2P+T	100/130 V	50 / 60 Hz	4	555151	555351
16 A	3P+T	100/130 V	50 / 60 Hz	4	555152	
16 A	2P+T	200/250 V	50 / 60 Hz	6	555154	555354
16 A	3P+T	200/250 V	50 / 60 Hz	9	555155	555355
16 A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555156	555356
16 A	2P+T	380/415 V	50 / 60 Hz	9	555157	
16 A	3P+T	380/415 V	50 / 60 Hz	6	555158	555358
16 A	4P+T	200/346 V to 240/415 V	50 / 60 Hz	6	555159	555359
16 A	3P+T	440/460 V	60 Hz	11	555160	
16 A	3P+T	480/500 V	50 / 60 Hz	7	555162	555362
16 A	4P+T	277/480 V to 288/500 V	50 / 60 Hz	7	555163	
32 A	2P+T	100/130 V	50 / 60 Hz	4	555251	555451
32 A	2P+T	200/250 V	50 / 60 Hz	6	555254	555454
32 A	3P+T	200/250 V	50 / 60 Hz	9	555255	555455
32 A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555256	555456
32 A	2P+T	380/415 V	50 / 60 Hz	9	555257	
32 A	3P+T	380/415 V	50 / 60 Hz	6	555258	555458
32 A	4P+T	200/346 V to 240/415 V	50 / 60 Hz	6	555259	555459
32 A	3P+T	440/460 V	60 Hz	11	555260	
32 A	3P+T	480/500 V	50 / 60 Hz	7	555262	555462
32 A	4P+T	277/480 V to 288/500 V	50 / 60 Hz	7	555263	555463



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: **Julien Gauthier**
Certification Officer

Date: 28/01/2021

ANNEX (Continued)

Straight plug					References	
Current	Number of poles	Voltage	Frequency	Earthing position	IP 44	IP 66-67
16 A	2P+T	100/130 V	50 / 60 Hz	4	555121	555321
16 A	3P+T	100/130 V	50 / 60 Hz	4	555122	
16 A	2P+T	200/250 V	50 / 60 Hz	6	555124	555324
16 A	3P+T	200/250 V	50 / 60 Hz	9	555125	555325
16 A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555126	555326
16 A	2P+T	380/415 V	50 / 60 Hz	9	555127	
16 A	3P+T	380/415 V	50 / 60 Hz	6	555128	555328
16 A	4P+T	200/346V to 240/415 V	50 / 60 Hz	6	555129	555329
16 A	3P+T	440/460 V	60 Hz	11	555130	
16 A	3P+T	480/500 V	50 / 60 Hz	7	555132	555332
16 A	4P+T	277/480V to 288/500 V	50 / 60 Hz	7	555133	
32 A	2P+T	100/130 V	50 / 60 Hz	4	555231	555431
32 A	2P+T	200/250 V	50 / 60 Hz	6	555234	555434
32 A	3P+T	200/250 V	50 / 60 Hz	9	555235	555435
32 A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555236	555436
32 A	2P+T	380/415 V	50 / 60 Hz	9	555237	
32 A	3P+T	380/415 V	50 / 60 Hz	6	555238	555438
32 A	4P+T	200/346 V to 240/415 V	50 / 60 Hz	6	555239	555439
32 A	3P+T	440/460 V	60 Hz	11	555240	
32 A	3P+T	440 V	60 Hz	3		555441
32 A	3P+T	480/500 V	50 / 60 Hz	7	555242	555442
32 A	4P+T	277/480 V to 288/500 V	50 / 60 Hz	7	555243	555443



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer


Date: 28/01/2021

ANNEX (Continued)

Connector					References	
Current	Number of poles	Voltage	Frequency	Earthing position	IP 44	IP 66-67
16A	2P+T	100/130 V	50 / 60 Hz	4	555101	555301
16A	3P+T	100/130 V	50 / 60 Hz	4	555102	
16A	2P+T	200/250 V	50 / 60 Hz	6	555104	555304
16A	3P+T	200/250 V	50 / 60 Hz	9	555105	555305
16A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555106	555306
16A	2P+T	380/415 V	50 / 60 Hz	9	555107	
16A	3P+T	380/415 V	50 / 60 Hz	6	555108	555308
16A	4P+T	200-346 V to 240/415 V	50 / 60 Hz	6	555109	555309
16A	3P+T	440/460 V	60 Hz	11	555110	
16A	3P+T	480/500 V	50 / 60 Hz	7	555112	555312
16A	4P+T	277/480 V to 288/500 V	50 / 60 Hz	7	555113	
32A	2P+T	100/130 V	50 / 60 Hz	4	555211	
32A	2P+T	200/250 V	50 / 60 Hz	6	555214	555414
32A	3P+T	200/250 V	50 / 60 Hz	9	555215	555415
32A	4P+T	120/208 V to 144/250 V	50 / 60 Hz	9	555216	555416
32A	2P+T	380/415 V	50 / 60 Hz	9	555217	
32A	3P+T	380/415 V	50 / 60 Hz	6	555218	555418
32A	4P+T	200/346 V to 240/415 V	50 / 60 Hz	6	555219	555419
32A	3P+T	440/460 V	60 Hz	11	555220	
32A	3P+T	440 V	60 Hz	3		555421
32A	3P+T	480/500 V	50/60 Hz	7	555222	555422
32A	4P+T	277/480 V to 288/500 V	50/60 Hz	7	555223	



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: **Julien Gauthier**
Certification Officer


Date: 28/01/2021

ANNEX (End)

Type of accessory	- Socket outlet - Plugs - Connectors
Rated operating voltage:	2P+E : 100/130 V or 200/250 V 3P+E: : 200/250 V, 380/415 V, 440/460 V or 480/500 V, 3P+N+E: 120/208 V to 144/250 V, 200/346 V to 240/415 V, 277/480 V to 288/500 V
Rated current:	16-32A
Degree of protection:	IP44, IP66/67
Standard sheet:	2-I, 2-II
Position of earthing contact:	4h, 6h, 7h, 9h, 11h
Keyway position:	without
Type of terminal:	Screw-type
Plugs and connectors	
Type of cable exit:	Straight
Appliance inlet and socket-outlet	
Type of installation:	panel type – surface-type



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: *Julien Gauthier*
Julien Gauthier
Certification Officer

Date: 28/01/2021