

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Empty enclosures for low-voltage switchgear and controlgear assemblies

Name and address of the applicant

LEGRAND FRANCE
6, Paul Nouel, 76770 MALAUNAY - France

Name and address of the manufacturer

LEGRAND FRANCE
6, Paul Nouel, 76770 MALAUNAY - France

Name and address of the factory

OTIMA
Z.I. de l'Aumallerie 9 rue Henri Bequerel,
35133 LA SELLE EN LUITRE - France

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See annex

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Series Atlantic stainless steel cabinet
References: see annex

Additional information (if necessary may also be reported on page 2)

/
 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 62208:2011(ed.2)

As shown in the Test Report Ref. No. which forms part of this Certificate

148063-702068

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 07/08/2017

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX 1


REFERENCES, MAINS CHARACTERISTICS

Part Number		rating	Option	Sizes (mm)	Door lock
304L	316L				
0 352 00	0 352 40	IP66 IK 10	Single door	300x200x160	1
0 352 01	0 352 41	IP66 IK 10		400x300x200	1
0 352 02	0 352 42	IP66 IK 10		500x400x200	2
0 352 03	-	IP66 IK 10		600x400x200	2
0 352 05	0 352 45	IP 66 IK10		600x400x250	2
0 352 06	0 352 46	IP 66 IK10		700x500x250	2
0 352 07	-	IP 66 IK10		400x400x200	1
0 352 08	-	IP 66 IK10		400x600x250	1
0 352 09	-	IP 66 IK10		600x600x250	2
0 352 11	0 352 47	IP 66 IK10		800x600x300	2
0 352 12	-	IP 66 IK10		800x800x300	2
0 352 13	0 352 53	IP 66 IK10		1000x800x300	2
0 352 14	-	IP 66 IK10		1200x800x300	2
0 352 15	-	IP 66 IK10		1400x800x400	2
0 352 55	-	IP 66 IK 10		500x500x250	2
0 352 16	-	IP 55 IK10	Double doors	1200x1000x300	1 (Door Handle) Closing by 3-point locking system
0 352 21	-	IP66 IK 10	Glass door	400x300x200	1
0 352 22	-	IP66 IK 10		500x400x200	2
0 352 24	-	IP66 IK 10		600x400x200	2
0 352 25	-	IP66 IK 10		600x400x250	2
0 352 26	-	IP66 IK 10		700x500x250	2
0 352 31	-	IP66 IK 10		800x600x300	2
0 352 33	-	IP66 IK 10		1000x800x300	2
0 352 75	-	IP66 IK 10		500x500x250	2
0 352 76	-	IP66 IK 10	1200x800x300	2	

Type of material	metallic
Method of fixing	wall mounting
Intended location	Outdoor
Degree of protection	IP55 (double doors) IP 66 (single door) IK 10



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 07/08/2017

Signature: **Jean-François BRUEL**
Certification Officer