

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


CB TEST CERTIFICATE

Product	Empty enclosures for low-voltage switchgear and controlgear assemblies
Name and address of the applicant	LEGRAND FRANCE 6, Paul Nouel 76770 MALAUNAY - FRANCE
Name and address of the manufacturer	LEGRAND FRANCE 6, Paul Nouel 76770 MALAUNAY - FRANCE
Name and address of the factory	LEGRAND FRANCE 6, Paul Nouel 76770 MALAUNAY - FRANCE
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	300x200x160 to 1400x800x400: IP66, single door 600x800x300 to 1200x1200x400: IP55, double door
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	CTF2
Model / Type Ref.	Atlantic steel cabinet RAL 7035 Models : 0 354 xx – 0 355 xx – 0 369 xx (xx) References : see annex
Additional information (if necessary may also be reported on page 2)	/ <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62208:2011(ed.2)
As shown in the Test Report Ref. No. which forms part of this Certificate	152045-713355

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 18/06/2018

Signature: **Jean-François BRUEL**
Certification Officer


ANNEX

REFERENCES, RATINGS AND MAIN CHARACTERISTICS:

Sizes (mm)			France range references (without plain plate)		Export range references (supplied with plain plate)	
			Metal IP 66 (1door) IP55 (2 doors)		Metal IP 66 (1 door) IP55 (2 doors)	
H	L	P	/	Glass door	/	Glass door
300	200	160	0 355 00(1)with plain plate		0 369 10 ⁽¹⁾	
400	300	160	0355 09 ⁽¹⁾		0 369 12 ⁽¹⁾	
500	400	160			0 369 13 ⁽¹⁾	
400	300	200	0 355 02	0 354 92	0 369 17	0 369 27
500	400	200	0 355 03	0 354 93	0 369 18	0 369 28
600	400	200	0 355 04		0 369 19	0 369 29
600	500	200			0 369 20	
700	500	200			0 369 21	
500	400	250	0 355 07		0 369 25	
600	400	250	0 355 08	0 354 94	0 369 26	0 369 36
700	500	250	0 355 12	0 354 95	0 369 30	0 369 40
800	600	250	0 355 14		0 369 31	0 369 41
1000	600	250	0 355 17		0 369 32	
1000	800	250	0 355 18		0 369 33	
700	500	300	0 355 22			
800	600	300	0 355 23	0 354 96	0 369 37	0 369 47
1000	600	300	0 355 26		0 369 38	0 369 48
1000	800	300	0 355 27	0 354 97	0 369 39	0 369 49
1200	600	300			0 369 42	
1200	800	300	0 355 92		0 369 43	
1200	1000	300	0 355 93 ⁽²⁾			
1400	1000	300	0 355 95 ⁽²⁾			
800	600	400	0 355 28		0 369 44	
1000	800	400	0 355 29		0 369 45	
1200	800	400	0 355 96		0 369 46	0 369 56
1400	800	400	0 355 98		0 369 50	0 369 60



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 18/06/2018

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX (end)

France range references (without plain plate)			Export range references (supplied with plain plate)		France range references (without plain plate)	
			Metal IP 66 (1door) IP55 (2 doors)		Metal IP 66 (1 door) IP55 (2 doors)	
H	L	P	/	Glass door	/	Glass door
300	300	160	0 355 05 ⁽¹⁾		0 369 51 ⁽¹⁾	
300	300	200	0 355 30		0 369 55	
400	400	200	0 355 31		0 369 57	
500	500	200			0 369 59	
500	500	250	0 355 32		0 369 62	
600	600	250	0 355 10		0 369 64	0 369 74
800	800	250	0 355 15			
600	600	300	0 355 20			
800	800	300	0 355 24		0 369 68	
1000	1000	300	0 355 91 ⁽²⁾			
1200	1200	300	0 355 94 ⁽²⁾			
600	600	400	0 355 36		0 369 72	
1200	1200	400	0 355 97 ⁽²⁾			
300	400	160			0 369 11 ⁽¹⁾	
300	400	200	0 355 01		0 369 75	
400	600	200			0 369 76	
400	600	250	0 355 06		0 369 77	
800	1000	250	0 355 33 ⁽²⁾			
600	800	300	0 355 21 ⁽²⁾		0 369 78 ⁽²⁾	
600	1000	300	0 355 37 ⁽²⁾		0 369 79 ⁽²⁾	
800	1000	300	0 355 34 ⁽²⁾		0 369 80 ⁽²⁾	
1000	1200	300	0 355 90 ⁽²⁾		0 369 81 ⁽²⁾	


(1): Without cable entry

(2): double doors

For more information relating to the ratings and the main characteristics please refer to the CB Test Report:
152045-713355



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15745000 €
RCS Nanterre 3408763174
33 Avenue du Général Leclerc
F – 92266 FONTENAY AUX ROSES

Date: 18/06/2018

Signature: **Jean-François BRUEL**
Certification Officer