



Ref. Certif. No.

FR_705863

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Boxes and enclosures for electrical accessories

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series : BATIBOX_Flush-mounting boxes for dry partitions
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR 571665C dated 12/06/2008. Update further to the evolution of the standard(s) and addition of product references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

60046568-546906, 81539-571662, 159775-732850A, 159775-732850B

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: **Julien Gauthier**
Certification Officer

Date: 24/07/2019

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

ERP ELBROMPLAST

CALEA VIDRIGHIN, STAN N° 13A
300571 TIMISOARA
ROMANIA



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 24/07/2019



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 366 574
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:  **Julien Gauthier**
Certification Officer

ANNEX (Continued)

Boxes BATIBOX

Reference	Capacity		Depth (mm)	Dimensions (mm)	Spacing (mm)
	gang	modules			
0 800 40		1	40	35,5 x 76,5	-
0 905 39		1	40	35,5 x 76,5	-
0 800 41	1		40	Φ 67	-
0 800 06	1		40	Φ 67	-
0 800 08	1		40	Φ 67	-
0 905 41	1		40	Φ 67	-
200 186	1		40	Φ 67	-
200 315	1		40	Φ 67	-
200 319	1		40	Φ 67	-
391 990	1		40	Φ 67	-
0 800 42	2	4/5	40	Φ 67	71
0 905 42	2	4/5	40	Φ 67	71
0 800 43	3	6/8	40	Φ 67	71
0 905 43	3	6/8	40	Φ 67	71
0 800 44	4	8/10	40	Φ 67	71
0 905 44	4	8/10	40	Φ 67	71
0 800 49		3	40	71 x 111	-
0 800 51	1		50	Φ 67	-
391 991	1		50	Φ 67	-
0 800 09	1		50	Φ 67	-
0 800 52	2	4/5	50	Φ 67	71
0 800 53	3	6/8	50	Φ 67	71
0 800 54	4	8/10	50	Φ 67	71
0 800 61	1		60	Φ 67	-
1 893 52	2		50	Φ 67	57
1 893 53	3		50	Φ 67	57
0 919 85	1		40	Φ 85	-



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 263 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Julien Gauthier
Certification Officer

Date: 24/07/2019

ANNEX (End)

Nature of their material.	Insulating	
Method of installation.	Flush:	Hollow walls, hollow ceilings, hollow floors or furniture.
Type of inlets (outlets)	With inlets for plain or corrugated conduits.	
Clamping means.	Without clamping means.	
Minimum and maximum temperatures during installation.	-5°C to +60 °C	
Boxes and enclosures for hollow walls and the like.	Degree of protection of the part mounted in the hollow wall.	IP20
Arrangements to fix the accessories to the boxes.	Boxes fitted out with screws.	

ACCESSORIES

References	Description
0 897 48	Long screw 40 mm
0 800 71	Removable divider for multi-gang boxes depth 40mm
0 800 72	Removable divider for multi-gang boxes depth 50mm



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 24/07/2019



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 263 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Julien Gauthier
Certification Officer