



Ref. Certif. No.

FR_707135

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Box for accessories

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series : ECOBATIBOX
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR 668320B/M1 dated 05/05/2017 Update further to the evolution of the standard(s), addition of product references, addition of factory

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

147883-701669, 159775-732856A, 159775-732856B

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: **Didier BOURGES**
Manager of Certification Operations

Date: 29/10/2019

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT

IPARTELEPI UT 14 PF 10
6600 SZENTES - HUNGARY



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 29/10/2019



Signature: **Didier BOURGES**
Manager of Certification Operations

ANNEX (End)

Mechanisms

References	Capacity		Depth (mm)	Ø / Diameter axes (mm)	Between axes (mm)
	gang	modules			
0 800 07	1	-	40	67	-
0 800 12	1	-	40	67	-
0 800 13	1	-	50	67	-
0 800 14	1	-	50	67	-
0 800 21	1	-	40	67	-
0 800 22	2	4/5	40	67	71
0 800 23	3	6/8	40	67	71
0 800 24	4	8/10	40	67	71
0 800 31	1	-	50	67	-
0 800 32	2	4/5	50	67	71
0 800 33	3	6/8	50	67	71
0 800 34	4	8/10	50	67	71
0 800 84	1	-	40	85	-
0 800 86	1	-	40	85	-
0 905 00	1	-	50	67	-
0 905 08	1	-	40	67	-
0 905 09	2	4/5	40	67	71
0 905 10	3	6/8	40	67	71
0 905 22	4	8/10	40	67	71
200 157	1	-	40	67	-
200 216	1	-	40	67	-
200 335	1 & 2	4/5	40	67	-

Rated insulation voltage	450 V~
Nature of material	Insulating material
Method of installation	Flush in :
	Hollow walls, hollow ceilings, hollow floors or furniture
	Placement :
	Placement: Suitable for all types of installation except into concrete
Type of inlets (outlets)	With inlets for plain or corrugated conduits
Clamping means	Without clamping means
Minimum and maximum temperatures during installation	From -5°C to +60°C
Boxes and enclosures for hollow walls and the like	Degree of protection of the part mounted in the hollow wall : IP40
Arrangements to fix the accessories to the boxes	Boxes fitted out with screws
	Boxes destined to receive another fixing means

Reference	Diameter (mm)	Color
0 905 17	16	grey
0 905 18	20	
0 905 19	25	
05916	16	blue
05917		
05920		
05921	20	
05925		
05926		
05932	32	
05933		



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 29/10/2019



Signature: **Didier Boulet**
 Manager of Certification Operations