


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|--|
| Product | Switch for fixed electrical installation |
| Name and address of the applicant | LEGRAND FRANCE 159 RUE JEAN JOANNON ZI DES TROIS MOULINS 06606 ANTIBES FRANCE |
| Name and address of the manufacturer | LEGRAND FRANCE 159 RUE JEAN JOANNON ZI DES TROIS MOULINS 06606 ANTIBES FRANCE |
| Name and address of the factory | |
| Note: When more than one factory, please report on page 2 | <input checked="" type="checkbox"/> Additional Information on page 2 |
| Ratings and principal characteristics | See Annex |
| Trademark / Brand (if any) |  |
| Customer's Testing Facility (CTF) Stage used | CTF 2 |
| Model / Type Ref. | CX ³ series 4129 08, 4129 09, 4129 10, 4129 11, 4129 12, 4129 13, 4129 14, 4129 15, 4129 16, 4129 17, 4129 18, 4129 19, 4129 20, 4129 40 |
| Additional information (if necessary may also be reported on page 2) | Supersedes CBTC 664032B/M2 dated 14/01/2016 : update further to the evolution of the standard, addition one product reference <input type="checkbox"/> Additional Information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 60669-1:2017 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 167032-750467, 167032-750467/1 to 167032-750467/13 |


This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 27/08/2020

Signature



ANNEX

Name and address of the factories:**LEGRAND FRANCE**

159 RUE JEAN JOANNON ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

LEGRAND FRANCE

290 AVENUE DE COLMAR
67100 STRASBOURG
FRANCE

LEGRAND POLSKA SP. Z O.O.

UL. WARYNSKIEGO 20
57-200 ZABKOWICE SLASKIE
POLAND

LEGRAND ELEKTRIK SANAYI A.S

GOSB GEBZE ORGANIZE SANAYI BOLGESI - IHSAN DEDE CADDESİ N°112
41480 GEBZE KOCAELI
TURKEY



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 27/08/2020



Signature: Jérôme REINSSON
Certification Officer

References, ratings and main characteristics:

| References | With / without indicator | Pattern number | Contact | Method of actuating | Characteristics | |
|------------|--------------------------|----------------|-------------|---------------------|-----------------|---------------|
| 4129 08 | without | 1 | 1 NO | Push-button | 20 AX, 250 V~ | |
| 4129 09 | without | 1 | 1 NC | | | |
| 4129 10 | without | 2 | 2 NO | Control switch | | |
| 4129 11 | without | 2 | 1 NO + NC | | | |
| 4129 12 | with 12/48 V ac / dc * | 1 | 1 NO | | | |
| 4129 13 | with 12/48 V ac / dc * | 1 | 1 NC | | | |
| 4129 14 | with 110/400 V~ | 1 | 1 NO | | | |
| 4129 15 | with 110/400 V~ | 1 | 1 NC | | | |
| 4129 16 | without | 2 | 1 NO + 1 NC | Push-button | | 20 AX, 250 V~ |
| 4129 17 | without | 2 | 1 NO + 1 NO | | | 20 A, 250 V~ |
| 4129 18 | with 12/48 V ac / dc * | 1 | 1 NO | Push-button | 20 AX, 250 V~ | |
| 4129 19 | with 12/48 V ac / dc * | 1 | 1 NC | | | |
| 4129 20 | with 110/400 V~ | 1 | 1 NO | | | |
| 4129 40 | with 110/400 V~ | 1 | 1 NC | | | |


* : ~ / ==

| | |
|------------------------|-----------------|
| Contact opening | normal gap |
| Protection degree | IP20 |
| Method of actuating | See above table |
| Method of mounting | panel-type |
| Method of installation | design A |
| Type of terminals | screw-type |
| Flexible cable outlet | without |



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 27/08/2020



Signature: Jérôme REYSSON
Certification Officer