



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Tito Livio, 5 – 24123 – BERGAMO (Italy)
+390354175244 fax. +390354534662 e-mail:acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. IT 12.074

Apparatus

Three phases low voltage switchgear 415V (U_n/U_e) – 690V (U_i) – 8kV (U_{imp})
– 50kA (I_{cw}) – 50Hz – 800A (I_{nA})

Designation

XL³ 800 - VX³ 800 Arrangement 71

Manufacturer or responsible vendor

Legrand S.n.c. – 128, Av. du Maréchal-de-Lattre-de-Tassigny
87045 Limoges Cedex (France)

Tested for: Legrand S.n.c.

Tested by: ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011.

10.11 Short circuit withstand strength


The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below:

I_{cw} 50kA for 0,5 seconds

This document includes Test report No. : 12.135

Issue date: 2012.10.11

Responsible Certification Body : ACAE
Mauro Marchi



Authorized signature

Date: 2012.10.29

This certificate applies only to the apparatus tested. The possibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) allowing the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) in which are stated the tests performed and the assigned rated characteristics of the apparatus Tested, are permitted without written permission from the LOVAG Laboratory responsible for this Certificate.

Validity of this certificate is linked to the ACAE certification scheme.



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements