



Attestation of Conformity

ISO/IEC, EN & TIA Screened Class E_A / Category 6A Two Connector Permanent Link

Legrand
128 Avenue de Lattre de Tassigny
F-87045 Limoges Cedex, France

Attestation of Conformity No. 1191062

This type of Class E_A / Category 6A screened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of edition 1.0 of ISO/IEC 11801-1:2017 and CENELEC EN 50173-1:2018, and Category 6A requirements of ANSI/TIA-568.2-D:2018. The Attestation of Conformity is only valid for the actually tested permanent link type in T568B designation connected with RJ 45 plugs from Legrand patch cords P/N 51866 / 67 / 68 / 69 / 70 / 71 / 72 / 73, and consisting of the following Legrand components:

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N 328 82</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Patch Panel,</i>	<i>P/N HD63</i>
	<i>Wall Outlet,</i>	<i>P/N SA63</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 15th August 2019

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 15th August 2019

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager