



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-150-15**

Valid from: 2022 02 12
until: 2024 02 12

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Plug for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 38291, 35182**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Wien, 2022 01 18

Dipl.-Ing. T. Neumayer

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Plug for industrial purposes

Type designation:

Rating:

Trademark:

033

Insulating voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

034

Insulating voltage: 690 V or 1000 V
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

035

Insulating voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

0332

Insulating voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

0342

Insulating voltage: 690 V or 1000 V
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

0352

Insulating voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

0331

Insulating voltage: 690 V
2P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

0341

Insulating voltage: 690 V or 1000 V
3P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

0351

Insulating voltage: 690 V
3P+N+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

03321

Insulating voltage: 690 V
2P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

03421

Insulating voltage: 690 V or 1000 V
3P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

03521

Insulating voltage: 690 V
3P+N+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.


Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz
033 0331 0332 03321	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
034 0341 0342 03421	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380 440	50 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		8	1000	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
		12	Supply from an isolating transformer	50 and 60
035 0351 0352 03521	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	220/380 250/440	50 60
		4	57/100 – 75/130	50 and 60
		5	347/600 – 400/690	50 and 60
		6	200/346 – 240/415	50 and 60
		7	277/480 – 288/500	50 and 60
		9	120/208 – 144/250	50 and 60
		10	>50	>100 - 300
		11	250/440 – 265/460	60
		12	Supply from an isolating transformer	50 and 60

033, 034, 035, 0331, 0341, 0351with pilot contact
0332, 0342, 0352, 03321, 03421, 03521without pilot contact

Accessories:

ts7632 •



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.