



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-151-15**

Valid from: 2022 02 25
until: 2024 02 25

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Connector for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 38292, 35181**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2022 01 18



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Connector for industrial purposes

Type designation:

Rating:

Trademark:

2335

Insulating voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

2345

Insulating voltage: 690 V or 1000 V
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

2355

Insulating voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

233

Insulating voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

234

Insulating voltage: 690 V or 1000 V
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

235

Insulating voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

23351

Insulating voltage: 690 V
2P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

23451

Insulating voltage: 690 V or 1000 V
3P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

23551

Insulating voltage: 690 V
3P+N+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

2331

Insulating voltage: 690 V
2P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

2341

Insulating voltage: 690 V or 1000 V
3P+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

2351

Insulating voltage: 690 V
3P+N+PE
IP 44
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz		
233 2331 2335* 23351*	63	1	Other ratings	Other ratings		
		2	>50	>300 - 500		
		3	>50 - 250	DC		
		4	100 – 130	50 and 60		
		6	200 – 250	50 and 60		
		7	480 – 500	50 and 60		
		8*	>250	DC		
		9	380 – 415	50 and 60		
		10	>50	>100 - 300		
		12	Supply from an isolating transformer	50 and 60		
234 2341 2345* 23451*	63	1	Other ratings	Other ratings		
		2	>50	>300 - 500		
		3	380 440	50 60		
		4	100 – 130	50 and 60		
		5	600 – 690	50 and 60		
		6	380 – 415	50 and 60		
		7	480 - 500	50 and 60		
		8*	1000	50 and 60		
		9	200 – 250	50 and 60		
		10	>50	>100 - 300		
		11	440 – 460	60		
				12	Supply from an isolating transformer	50 and 60
		235 2351 2355 23551	63	1	Other ratings	Other ratings
2	>50			>300 - 500		
3	220/380 250/440			50 60		
4	57/100 – 75/130			50 and 60		
5	347/600 – 400/690			50 and 60		
6	200/346 – 240/415			50 and 60		
7	277/480 – 288/500			50 and 60		
9	120/208 – 144/250			50 and 60		
10	>50			>100 - 300		
11	250/440 – 265/460			60		
				12	Supply from an isolating transformer	50 and 60

233, 234, 235, 2331, 2341, 2351..... with pilot contact

2335, 2345, 2355, 23351, 23451, 23551..... without pilot contact

* Types 2335, 23351 8h / >250V DC additional marking:

* Types 2345, 23451 8h / 1000V AC only for type 2345, additional marking:

“Only for use with electrical interlock”

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.