



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-216-05**

Valid from: 2022 02 18  
until: 2024 02 18

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Plug for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 35318**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*  
Digitally signed by T. Neumayer  
Email=t.neumayer@ove.at



Wien, 2022 01 18

Dipl.-Ing. T. Neumayer

## **OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01  
IEC 60309-1:1999 + A1:2005 + A2:2012  
IEC 60309-2:1999 + A1:2005 + A2:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Plug for industrial purposes**

**Type designation:**

*Rating:*

**Trademark:**

**013**

Rated current: 16 A  
2P+E  
IP44 or IP44/IP54  
plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**8013**

Rated current: 16 A  
2P+E  
IP44 or IP44/IP54  
angled plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**014**

Rated current: 16 A  
3P+E  
IP44 or IP44/IP54  
plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**7014**

Rated current: 16 A  
3P+E  
IP44 or IP44/IP54  
phase inverter straight  
screw terminals

PCE / ELCEE / SIROX / METECEE

**7414**

Rated current: 16 A  
3P+E  
IP44 or IP44/IP54  
phase inverter angled  
screw terminals

PCE / ELCEE / SIROX / METECEE

**8014**

Rated current: 16 A  
3P+E  
IP44 or IP44/IP54  
angled plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**015**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**7015**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
Phase inverter straight  
screw terminals

PCE / ELCEE / SIROX / METECEE

**7415**

Rated current: 16 A  
3P+N+E  
IP44 oder IP44/IP54  
phase inverter angled  
screw terminals

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**8015**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
angled plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**0132**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**80132**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
angled plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**0142**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**70142**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
phase inverter straight  
screw terminals

PCE / ELCEE / SIROX / METECEE

**74142**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
phase inverter angled  
screw terminals

PCE / ELCEE / SIROX / METECEE

**80142**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
angled plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**0152**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**70152**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
phase inverter straight  
screw terminals

PCE / ELCEE / SIROX / METECEE

**74152**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
phase inverter angled  
screw terminals

PCE / ELCEE / SIROX / METECEE

**80152**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
angled plug  
screw terminals

PCE / ELCEE / SIROX / METECEE

**013TT**

Rated current: 16 A  
2P+E  
IP44 or IP44/IP54  
plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**8013TT**

Rated current: 16 A  
2P+E  
IP44 or IP44/IP54  
angled plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**014TT**

Rated current: 16 A  
3P+E  
IP44 or IP44/IP54  
plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**8014TT**

Rated current: 16 A  
3P+E  
IP44 or IP44/IP54  
angled plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**015TT**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**7015TT**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
phase inverter straight  
screw and screwless terminals

PCE / ELCEE / SIROX / METECEE

**7415TT**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
phase inverter angled  
screw and screwless terminals

PCE / ELCEE / SIROX / METECEE

**8015TT**

Rated current: 16 A  
3P+N+E  
IP44 or IP44/IP54  
angled plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**0132TT**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**80132TT**

Rated current: 16 A  
2P+E  
IP67 or IP66/IP67  
angled plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**0142TT**

Rated current: 16 A  
3P+E  
IP67 or IP66/IP67  
plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**80142TT**

Rated current: 16 A  
3P+E  
IP67 or IP66/IP67  
angled plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**0152TT**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

**70152TT**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
phase inverter straight  
screw and screwless terminals

PCE / ELCEE / SIROX / METECEE

**74152TT**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
phase inverter angled  
screw and screwless terminals

PCE / ELCEE / SIROX / METECEE

**80152TT**

Rated current: 16 A  
3P+N+E  
IP67 or IP66/IP67  
angled plug  
screwless terminals

PCE / ELCEE / SIROX / METECEE

---

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

### Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
013 8013 0132 80132	16	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 – 250	DC	690
		4	100 – 130	50 and 60	690
		6	200 – 250	50 and 60	690
		7	480 – 500	50 and 60	690
		8	>250	DC	690
		9	380 – 415	50 and 60	690
		10	>50	>100 - 300	690
		12	Supply from an isolating transformer	50 and 60	690
014 7014*) 7414*) 8014 0142 70142*) 74142*) 80142	16	1	Other ratings	Other ratings	500*), 690
		2	>50	>300 - 500	500*), 690
		3	380 440	50 60	500*), 690
		4	100 – 130	50 and 60	500*), 690
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	500*), 690
		7	480 - 500	50 and 60	500*), 690
		9	200 – 250	50 and 60	500*), 690
		10	>50	>100 - 300	500*), 690
		12	Supply from an isolating transformer	50 and 60	500*), 690
015 7015*) 7415*) 8015 0152 70152*) 74152*) 80152	16	1	Other ratings	Other ratings	500*), 690
		2	>50	>300 - 500	500*), 690
		3	220/380 250/440	50 60	500*), 690
		4	57/100 – 75/130	50 and 60	500*), 690
		5	347/600 – 400/690	50 and 60	690
		6	200/346 – 240/415	50 and 60	500*), 690
		7	277/480 – 288/500	50 and 60	500*), 690
		9	120/208 – 144/250	50 and 60	500*), 690
		10	>50	>100 - 300	500*), 690
		11	250/440 – 265/460	60	500*), 690
12	Supply from an isolating transformer	50 and 60	500*), 690		

\*) 7014, 7015, 7414, 7415, 70142, 70152, 74142, 74152  
with insulation voltage 500 V

#### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
013TT 8013TT 0132TT 80132TT	16	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 – 250	DC	690
		4	100 – 130	50 and 60	690
		6	200 – 250	50 and 60	690
		7	480 – 500	50 and 60	690
		8	>250	DC	690
		9	380 – 415	50 and 60	690
		10	>50	>100 - 300	690
		12	Supply from an isolating transformer	50 and 60	690
014TT 8014TT 0142TT 80142TT	16	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 – 130	50 and 60	690
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 – 250	50 and 60	690
		10	>50	>100 - 300	690
		11	440 – 460	60	690
				12	Supply from an isolating transformer
015TT 7015TT*) 7415TT*) 8015TT 0152TT 70152TT*) 74152TT*) 80152TT	16	1	Other ratings	Other ratings	500*), 690
		2	>50	>300 - 500	500*), 690
		3	220/380 250/440	50 60	500*), 690
		4	57/100 – 75/130	50 and 60	500*), 690
		5	347/600 – 400/690	50 and 60	690
		6	200/346 – 240/415	50 and 60	500*), 690
		7	277/480 – 288/500	50 and 60	500*), 690
		9	120/208 – 144/250	50 and 60	500*), 690
		10	>50	>100 - 300	500*), 690
		11	250/440 – 265/460	60	500*), 690
				12	Supply from an isolating transformer

\*) 7015TT, 7415TT, 70152TT, 74152TT  
with insulation voltage 500 V

### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.