We, Eaton Industries GmbH, 53105 Bonn, Germany, Hein-Moeller-Str. 7-11, 53115 Bonn, Germany

declare under our sole responsibility as manufacturer that the product (family)

Insulation monitoring relay - EMR6-R

according to the list on page 2 and provided that it is installed, maintained and used in the application intended for, with respect to the relevant manufacturer's instructions, installation standards and "good engineering practices", complies with the statutory requirements:

2016 No. 1101 The Electrical Equipment (Safety) Regulations 2016
 2016 No. 1091 The Electromagnetic Compatibility Regulations 2016

2012 No. 3032 RoHS in Electrical and Electronic Equipment Regulations 2012

based on compliance with the following standard(s):

EN 60947-5-1:2017 + AC:2020

EN 61326-2-4:2013

EN 61557-1:2007

EN 61557-8:2015


EN IEC 63000:2018

Bonn, 04.11.2021

i.A. Edgar Willems
Director Quality
Industrial Controls & Protection Division

i.A. Paolo D'Amico Head of Product Line Management Machine Operation & Control





Bonn, 04.11.2021

i.A. Edgar Willems
Director Quality
Industrial Controls & Protection Division

i.A. Paolo D'Amico Head of Product Line Management Machine Operation & Control

