

# Declaration of conformity

UK  
CE

We, Eaton Electrical Products Ltd.  
Melton Road, Burton-on-the-Wolds, Leicestershire, LE12 5TH, UK

declare under our sole responsibility as manufacturer that the product (family)

## Size 03, 500V fuse-links with blade contacts (NH fuse system)

according to the list on page 2 and provided that it is installed, maintained and used in the application intended for, with respect to the relevant manufacturer's instructions, installation standards and "good engineering practices", complies with the statutory requirements:

2016 No. 1101      *The Electrical Equipment (Safety) Regulations 2016*

2012 No. 3032      *RoHS in Electrical and Electronic Equipment Regulations 2012*

based on compliance with the following standard(s):

EN 60269-1:2007 + A1:2009 + A2:2014

EN IEC 63000:2018

HD 60269-2:2013

Leicestershire, 13.08.2021



i.A. Edgar Willems  
Director Quality  
Industrial Controls & Protection Division



i.A. Bill Butters  
Head of Product Line Management  
Power Switching & Protection

